


BRITISH STANDARD  
METHODS OF TESTING  
VULCANIZED  
RUBBER

**PART C 3 : DETERMINATION OF  
PERMITTIVITY AND POWER FACTOR  
OF INSULATING SOFT VULCANIZED  
RUBBER AND EBONITE**

**B.S. 903 : Part C 3 : 1956**

Incorporating amendments issued November 1962 (PD 4722)  
and December 1965 (PD 5703)

£1.80  
Price  net

**BRITISH STANDARDS INSTITUTION**

Incorporated by Royal Charter

British Standards House, 2 Park St., London, W1Y 4AA

Telegrams: Standards London W1

Telephone: 01-629 9000

### CO-OPERATING ORGANIZATIONS

The Rubber Industry Standards Committee, under whose supervision this British Standard was prepared, consists of representatives from the following Government departments and industrial organizations:—

Board of Trade

- \*British Rubber Producers' Research Association
- \*Federation of British Rubber and Allied Manufacturers' Associations
- \*Institution of the Rubber Industry
- \*Ministry of Supply
- Natural Rubber Development Board
- \*Research Association of British Rubber Manufacturers
- \*Rubber Growers' Association

The Government departments and scientific and industrial organizations marked with an asterisk in the above list, together with the following, were directly represented on the committee entrusted with the preparation of this British Standard:—

Admiralty

Air Ministry

Association of British Chemical Manufacturers

Association of British Ebonite Manufacturers

British Cellular Rubber Manufacturers' Association

British Chemical Plant Manufacturers' Association

British Electrical and Allied Industries Research Association

British Railways, The British Transport Commission

British Rubber and Resin Adhesive Manufacturers' Association

Department of Scientific and Industrial Research

Department of the Government Chemist

General Post Office

Institute of Brewing

Institution of Chemical Engineers

Institution of Gas Engineers

Institution of Mechanical Engineers

Institution of Mechanical Engineers (Automobile Division)

Institution of Municipal Engineers

Institution of Water Engineers

London Advisory Committee for Rubber Research

(Ceylon and Malaya)

Ministry of Housing and Local Government

Ministry of Works

National College of Rubber Technology

National Physical Laboratory

Royal Institute of Chemistry

Rubber Trade Associations of London

Society of Motor Manufacturers and Traders Ltd.



THIS BRITISH STANDARD, having been approved by the Rubber Industry Standards Committee and endorsed by the Chairman of the Chemical Divisional Council, was published under the authority of the General Council on 27th June, 1956.

B.S. 903, first published June, 1940.

B.S. 903, first revision October, 1950.

First published as B.S. 903 : Part C 3, June, 1956.

The Institution desires to call attention to the fact that this British Standard does not purport to include all the necessary provisions of a contract.

In order to keep abreast of progress in the industries concerned, British Standards are subject to periodical review. Suggestions for improvements will be recorded and in due course brought to the notice of the committees charged with the revision of the standards to which they refer.

A complete list of British Standards, numbering over 5000, indexed and cross-indexed for reference, together with an abstract of each standard, will be found in the Institution's Yearbook, price £1.

This standard makes reference to the following British Standards:

B.S. 870. External micrometers.

B.S. 907. Dial gauges for linear measurement.

B.S. 2067. Determination of power factor and permittivity of insulating materials (Hartshorn and Ward method).

*British Standards are revised, when necessary, by the issue either of amendment slips or of revised editions. It is important that users of British Standards should ascertain that they are in possession of the latest amendments or editions.*

The following B.S.I. references relate to the work on this standard:—  
Committee reference RUC/10/6. Draft for comment CV(RUC) 5413

BRITISH STANDARD  
METHODS OF TESTING  
VULCANIZED RUBBER

Part C 3 : Determination of Permittivity and  
Power Factor of Insulating Soft Vulcanized  
Rubber and Ebonite

FOREWORD

*This British Standard has been published under the authority of the Rubber Industry Standards Committee. In deciding to issue a revision of the 1950 edition, it has also been considered desirable to publish B.S. 903 in separate parts and the present part replaces Part 34 of 1950. The main differences are in the adoption of metric dimensions and in the layout.*

*The group of parts in which the prefix letter 'C' is used covers methods of testing the electrical properties of rubber and ebonite. Further parts in this group have been issued as follows:*

- Part C 1. Determination of surface resistivity of insulating soft vulcanized rubber and ebonite.*
- Part C 2. Determination of volume resistivity of insulating soft vulcanized rubber and ebonite.*

SECTION 1 DEFINITIONS

For the purposes of this British Standard the following definitions shall apply:—

*Permittivity.* The ratio of the electric flux density produced in a dielectric medium to that produced in free space by the same electric force. In effect it is the ratio of the capacitance of a condenser having the material as dielectric to the capacitance of a similar condenser having air, or more precisely a vacuum, as dielectric.

*Power factor.* The sine of the loss angle, i.e. the angle by which the angle of lead of the current falls short of 90 degrees. In effect it is the ratio of the power loss in the material when used as the dielectric of a condenser to the product of the applied voltage and the resultant current. In dielectrics the property normally measured is the tangent of the loss angle; for small values of the loss angle this does not differ appreciably from the sine.



## SECTION 2 AUDIO FREQUENCY TEST

**2.1 Summary and explanatory note.** Permittivity and power factor at audio-frequencies are conveniently measured by means of a resistance-capacitance bridge network, the Schering bridge with Wagner earth attachment being a suitable network. These properties may change considerably with frequency and temperature, and the results of this test are valid for prediction of performance *only* for a narrow band of frequencies and temperatures in the vicinity of those adopted in the test.

**2.2 Test piece**

**2.21 *Soft rubber.*** The test piece shall be a disk with smooth surfaces not less than 100 mm in diameter, or not less than 200 mm in diameter, according to the size of electrodes to be used, and  $1.25 \pm 0.2$  mm in mean thickness. The variation in thickness within a given test piece shall not exceed 0.1 mm.

**2.22 *Ebonite.*** The test piece shall be a disk not less than 100 mm in diameter, or not less than 200 mm in diameter, according to the size of electrodes to be used, and not exceeding 3.5 mm in mean thickness. With disks approximating to this thickness, the mean thickness of test pieces used for comparative tests shall not vary by more than 1 mm. The variation in thickness within a given test piece shall not exceed 0.2 mm.

NOTE. The thickest permissible ebonite test piece, when tested with the small electrodes, may have a capacitance as low as 15 pF on which most commercial bridges would give a sensitivity of about  $\pm 0.003$  in  $\tan \delta$ . A further error of about 0.001 may occur on such test pieces when tested on a bridge without a Wagner earth due to the top electrode/guard ring capacitance. The sensitivity improves and the above error decreases with increased test piece capacitance.

**2.3 Electrodes.** The test piece shall be provided with electrodes and a guard ring. These shall take one of the following forms:—

**2.31 *Graphite.*** This shall be applied, before conditioning, in the form of a colloidal suspension in water. It is convenient to dilute the graphite suspension with distilled water to the consistency of drawing ink, and then to draw the circular outlines of the electrodes and guard ring on the surface of the test piece, afterwards painting the appropriate areas with the graphite suspension. Alternatively, the graphite may be applied by spraying, suitable stencils being used.

**2.32 *Metal foil.*** Disks of metal foil about 0.025 mm thick shall be applied, after conditioning, to the flat faces of the test piece, using a very thin coating of petroleum jelly or silicone grease as adhesive. The foil shall be pressed or rolled on to the surface and smoothed down until all irregularities are removed. It shall then be cut to the exact size which it is proposed to use for the electrodes. Alternatively the electrodes may

As altered  
Nov., 1962

be cut to shape before application. When the material under test is soft rubber, the period between application of the jelly or grease and testing shall be as short as possible.

**2.33 Mercury.** Suitable electrodes which shall be applied after conditioning and which can be modified to give the required dimensions are described in T. I. Jones, *Journal I.E.E.* 74, 185.

**2.34 Metal films.\*** Metal films of adequate thickness deposited in vacuo, either by sputtering or by volatilization, shall be applied before conditioning.

When graphite, metal foil or metal film electrodes are used, they and the guard ring shall be supplemented after conditioning by rigid brass backing plates which cover the electrodes.

The electrodes shall be circular, the upper electrode being surrounded by a guard ring. The dimensions of the electrodes, guard ring and plates, if any, shall be as given in Table 1 (see also Fig. 1):—

TABLE 1. DIMENSIONS OF ELECTRODES

	D <sub>1</sub>	D <sub>2</sub>	D <sub>3</sub> min.	D <sub>4</sub> min.
Large electrodes	cm 15.0	cm 15.4	cm 20	cm 20
Small electrodes	5.0	5.4	10	10




Fig. 1. Backing plate and electrode dimensions for permittivity and power factor test (audio frequency)

#### 2.4 Apparatus

**2.41 Schering bridge with Wagner earth.** A suitable form is shown in Fig. 2 and described below.

\* There may be difficulty in applying certain metals to soft rubber.






Fig. 2. Schering bridge for permittivity and power factor tests

The capacitor  $C_1$  is a variable air capacitor of good quality having a range of about 0–600 pF and  $C_2$  is a variable air capacitor of reasonably good quality of about the same range as  $C_1$ . The ratio arms are non-inductively wound and of equal value, 1000–10 000 ohms, each. The value used is 1000 ohms wherever possible, although a higher value may be necessary to obtain the required sensitivity.  $C_3$  and  $C_4$  are variable air capacitors of ordinary quality and a range of 0–1000 pF. When materials of high power factor are being measured, it may be necessary to connect additional capacitors, e.g. fixed mica capacitors of suitable value, in parallel with  $C_4$ . If three-terminal capacitors are used the screening is as shown; otherwise the screens of two-terminal capacitors are connected to the points  $b$  and  $c$  of the bridge.

The test piece with its electrodes form the capacitor  $C_t$ , which is screened as shown in Fig. 2.

The Wagner earthing arrangement consists of variable air-capacitors  $C_5$  and  $C_6$  of ordinary quality of range 0–500 pF and 0–1000 pF respectively ( $C_6$  being increased when necessary by the addition of fixed capacitors of suitable value) and a variable resistor  $R_6$ . It may be necessary to include the air-cored inductor  $L_6$  in one arm of the Wagner circuit in order to obtain balance.

The detector is a telephone, preferably of low resistance, or a valve detector, either of which is coupled to the bridge through a matching transformer which is screened electrically and magnetically. One pole of the secondary winding of the transformer is connected to the earth-point  $E$ . A switch  $S_1$  selects the detector positions: in the normal position it connects the detector between the points  $b$  and  $c$  of the bridge circuit, and in the other position it connects one side of the detector to earth and the other side to one junction point of the bridge.

The source of supply is connected to the points  $a$  and  $d$  of the bridge through a screened transformer with an earthed electrostatic screen between the primary and secondary windings, the voltage applied to the bridge being 100 to 150 volts. The source of supply shall be of reasonably good sine wave form of a frequency within the range 800–1600 c/s, but preferably of 1000 c/s. It shall be several yards away from the bridge unless it is carefully screened electro-magnetically from the detector.

**2.42** The instrument for measuring the thickness of soft rubber test pieces shall consist of a micrometer dial-gauge firmly held in a rigid stand over a flat base-plate of diameter at least 2 in. (51 mm). The gauge shall have a scale graduated in unit divisions of 0.001 in. or 0.01 mm and shall comply with the relevant requirements of B.S. 907\* for a Type A gauge. The plunger shall be fitted with a flat circular contact of diameter  $0.150 \pm 0.002$  in. ( $3.80 \pm 0.05$  mm), which is square to the plunger and parallel to the base-plate. The dial-gauge shall operate under a sub-

\* B.S. 907, 'Dial gauges for linear measurement'.



stantially dead-weight load of  $0.85 \pm 0.10$  oz ( $24 \pm 3$  g), equivalent to a pressure on the rubber of about 3 lb/sq. in. (200 g/sq. cm). For the most accurate results, the instrument shall be used as a comparator as recommended in B.S. 907, which also includes notes on the care and use of dial gauges. The dial gauge shall be capable of measuring the thickness at the centre of the test piece.

The thickness of ebonite test pieces shall be measured with a micrometer dial gauge or external micrometer capable of reaching the centre of the test piece and having flat measuring faces between  $\frac{1}{8}$  in. and  $\frac{1}{4}$  in. diameter (3–6 mm). (See also B.S. 870\* and 907.†)

## 2.5 Procedure

**2.51 Conditioning of samples and test pieces.** Tests should not be carried out less than 24 hours after vulcanization, and for accurate comparisons between different rubbers it may be necessary for these to be tested at substantially the same interval after vulcanization. Samples and test pieces shall be protected from light as completely as possible during the interval between vulcanization and testing.

Before conditioning and applying the electrodes each test piece shall be wiped carefully with absorbent paper or with a soft cloth.

The test pieces shall then be conditioned for not less than 18 hours and not more than 72 hours immediately before test as follows:—

- a. *Ebonite.* Relative humidity  $65 \pm 5$  per cent, temperature  $20 \pm 5^\circ\text{C}$ .
- b. *Soft rubber.* Relative humidity  $65 \pm 5$  per cent, temperature  $20 \pm 2^\circ\text{C}$ .

NOTE. See Note under 2.6, Temperature of test.

**2.52 Determination of permittivity and power factor.** When testing by means of the apparatus shown in Fig. 2 the following procedure shall be adopted:—

(i) With the lower electrode of the capacitor  $C_1$  connected to the bridge point *a* by means of the switch  $S_2$ , the detector shall be connected between the points *b* and *c* of the bridge and  $C_1$  set near its minimum value. The bridge circuit shall be roughly balanced by adjustment of  $C_2$  and  $C_4$ ,  $C_3$  having been set near its minimum value. The detector shall then be transferred to the Wagner circuit by means of the switch  $S_1$  and balance obtained by adjustment of  $C_5$ ,  $R_6$ ,  $L_6$  and  $C_6$ . The balancing procedure shall then be repeated, the bridge circuit and Wagner circuit being adjusted alternately until the balances converge.

(ii) With the lower electrode of the capacitor  $C_1$  connected to earth by means of the switch  $S_2$ , and with the detector connected between points *b* and *c* of the bridge, the bridge circuit shall be rebalanced by adjustment of  $C_1$  and  $C_4$  only. The Wagner and

\* B.S. 870, 'External micrometers'.

† B.S. 907, 'Dial gauges for linear measurement'.

bridge circuits shall be adjusted alternately as before until the balances converge.  $C_2$  and  $C_3$  shall not be altered during this operation.

(iii) Alternatively the adjustment (i) may be carried out with the lower electrode earthed and  $C_1$  set at a suitable value and adjustment (ii) with the lower electrode connected to the bridge point  $a$ .

**2.6 Temperature of test.** The test shall be carried out at a temperature of  $20 \pm 5^\circ\text{C}$  for ebonite and  $20 \pm 2^\circ\text{C}$  for soft rubber.

NOTE. A temperature of  $20^\circ\text{C}$  for conditioning and testing is not yet practicable for all countries. In tropical countries it is very difficult to maintain conditioning chambers or laboratories at this temperature and an alternative temperature of  $27^\circ\text{C}$  is therefore permitted. The tolerances should be as given in Clauses 2.51 and 2.6 for ebonite and soft rubber.

**2.7 Calculation of results.** Let  $C_4a$  and  $C_4b$  be the readings of  $C_4$ , and  $C_1a$  and  $C_1b$  the readings of  $C_1$  for balances with the lower electrode connected to  $a$  and to earth respectively, all readings being expressed in pico-farads.

The permittivity shall be calculated by the formula:

$$\epsilon = \frac{1.44 T (C_1b - C_1a)}{D^2}$$

where  $\epsilon$  = permittivity

$T$  = thickness of test piece in millimetres

$D$  = mean diameter in centimetres =  $\frac{D_1 + D_2}{2}$  where  $D_1$  is the diameter of the upper electrode and  $D_2$  is in the inner diameter of the guard ring.

The tangent of the loss angle ( $\tan \delta$ ) shall be calculated by the formula:

$$\tan \delta = \frac{2\pi f R C_1 b (C_4a - C_4b) \times 10^{-12}}{(C_1b - C_1a)}$$

where  $f$  = frequency in cycles per second

$R$  = resistance of the ratio arms in ohms

For values of  $\tan \delta$  up to 0.07 the difference between the value of  $\tan \delta$  and the power factor ( $\sin \delta$ ) is less than 1 part in 700.

**2.8 Report.** The report shall state:

1. Permittivity and power factor (for values of power factor greater than 0.07, it shall be stated whether the value refers to the power factor ( $\sin \delta$ ) or to  $\tan \delta$ ).
2. Frequency.
3. Size of electrode.
4. Type of electrode.
5. Temperature of test
6. Thickness of test piece.



## SECTION 3 RADIO-FREQUENCY TEST

**3.1 Summary and explanatory note.** Permittivity and power factor at radio frequencies are conveniently measured by means of the resonance method referred to below, in which the permittivity is obtained from the readings of a micrometer condenser into which the test piece is inserted, while the power factor is determined from the readings of a second micrometer condenser of very small range which serves to measure the sharpness of resonance and hence the power factor. Permittivity and power factor may change considerably with frequency and temperature, and the results of this test are valid for prediction of performance only for a narrow band of frequencies and temperatures in the vicinity of those adopted for the test.

**3.2 Test piece.** A flat disk  $53 \pm 1$  mm in diameter shall be used with the apparatus described in B.S. 2067.\* The most suitable thickness of test piece is that which will give a capacitance within the range 20–100 pF. It will generally be found in the range 1.00–2.50 mm.

The two faces of the test piece shall be flat. The variation in thickness in a given test piece shall not exceed 0.1 mm.

**3.3 Electrodes.** After the test piece has been conditioned it shall be provided with electrodes of metal foil 0.025–0.050 mm thick and 50 mm in diameter. The foils shall be applied concentrically to the specimen with the thinnest possible film of petroleum jelly or silicone grease, and shall be pressed on to the surface and smoothed down until all irregularities are removed. When the material under test is soft rubber, the period between application of the jelly or grease and testing shall be as short as possible.

Alternatively, metal films† of adequate thickness deposited in vacuo, either by sputtering or by volatilization, shall be applied and the test piece subsequently conditioned.

**3.4 Apparatus.** The apparatus shall be as described in B.S. 2067\* or any other apparatus which can be shown to give the same results.

The instrument for measuring the thickness of soft rubber test pieces shall consist of a micrometer dial-gauge firmly held in a rigid stand over a flat base-plate of diameter at least 2 in. (50 mm). The gauge shall have a scale graduated in unit divisions of 0.001 in. or 0.01 mm, and shall comply with the relevant requirements of B.S. 907‡ for a Type A gauge. The dial gauge shall be fitted with a flat contact square to the plunger and parallel to the base-plate and shall operate with a pressure of  $200 \pm 30$  gf/cm<sup>2</sup>. For the most accurate results, the instrument shall be

*As altered  
Dec., 1965*

\* B.S. 2067, 'Determination of power factor and permittivity of insulating materials (Hartshorn and Ward method)'.

† There may be difficulty in applying certain metal to soft rubber.

‡ B.S. 907, 'Dial gauges for linear measurement'.



used as a comparator as recommended in B.S. 907,\* which also includes notes on the care and use of dial gauges. The dial gauge shall be capable of measuring the thickness at the centre of the test piece.

NOTE. It is preferable for the gauge to have a contact of diameter about 4 mm as this may be used on almost all test pieces without any sub-part of the contact overhanging the test piece edge which would increase the contact pressure.

The thickness of ebonite test pieces shall be measured with a micrometer dial gauge or external micrometer capable of reaching the centre of the test piece and having flat measuring faces between  $\frac{3}{8}$  in. and  $\frac{1}{4}$  in. in diameter (3–6 mm). (See also B.S. 870† and 907.\*)

### 3.5 Procedure

**3.51 Conditioning of samples and test pieces.** Tests should not be carried out less than 24 hours after vulcanization, and for accurate comparisons between different rubbers it may be necessary to ensure that these are tested at substantially the same interval after vulcanization.

Samples and test pieces shall be protected from light as completely as possible during the interval between vulcanization and testing.

Before conditioning and applying the electrodes each test piece shall be wiped carefully with absorbent paper or with a soft cloth.

The test pieces shall then be conditioned for not less than 18 hours and not more than 72 hours immediately before test as follows:

- a. *Ebonite.* Relative humidity  $65 \pm 5$  per cent, temperature  $20 \pm 5^{\circ}\text{C}$ .
- b. *Soft rubber.* Relative humidity  $65 \pm 5$  per cent, temperature  $20 \pm 2^{\circ}\text{C}$ .

NOTE. See Note under 3.6, Temperature of test.

**3.52 Determination of permittivity and power factor.** When using the Hartshorn-Ward apparatus the most suitable procedure is that described in B.S. 2067,‡ Clause 7. The test shall normally be carried out at a frequency of approximately 1 Mc/s.

**3.6 Temperature of test.** The test shall be carried out at a temperature of  $20 \pm 5^{\circ}\text{C}$  for ebonite and  $20 \pm 2^{\circ}\text{C}$  for soft rubber.

NOTE. A temperature of  $20^{\circ}\text{C}$  for conditioning and testing is not yet practicable for all countries. In tropical countries it is very difficult to maintain conditioning chambers or laboratories at this temperature and an alternative temperature of  $27^{\circ}\text{C}$  is therefore permitted. The tolerances shall be as given in Clauses 3.51 and 3.6 for ebonite and soft rubber.

**3.7 Calculation of results.** When the Hartshorn-Ward method is used the permittivity and power factor shall be calculated as described in B.S. 2067,‡ Clause 7.

\* B.S. 907, 'Dial gauges for linear measurement'.

† B.S. 870, 'External micrometers'.

‡ B.S. 2067, 'Determination of power factor and permittivity of insulating materials (Hartshorn and Ward method)'.



**3.8 Report.** The report shall state:

1. Permittivity and power factor (for values of power factor greater than 0.07, it shall be stated whether the value refers to the power factor ( $\sin \delta$ ) or to  $\tan \delta$ ).
2. Frequency.
3. Method of test if other than Hartshorn-Ward.
4. Temperature of test.
5. Thickness of test piece.

## **BRITISH STANDARDS**

The following are available on application:

### **YEARBOOK**

Including subject index and numerical list of British Standards £1.

### **SECTIONAL LISTS. Gratis**

Acoustics (SL 10)  
Aerospace materials and components (SL 25)  
Automobile (SL 34)  
British Standard Handbooks (SL 27)  
Building (SL 16)  
Chemical engineering (SL 5)  
Chemicals, fats, glues, oils, soap, etc. (SL 4)  
Cinematography and photography (SL 1)  
Coal, coke and colliery requisites (SL 13)  
Codes of Practice (SL 8)  
Consumer goods (SL 3)  
Documentation, including Universal Decimal Classification (SL 35)  
Drawing practice (SL 37)  
Electrical engineering (SL 26)  
Farming, dairying and allied interests (SL 31)  
Furniture, bedding and furnishings (SL 11)  
Gardening, horticulture and landscape work (SL 41)  
Gas and solid fuel and refractories (SL 2)  
Glassware, excluding laboratory apparatus (SL 39)  
Heating, ventilating and air conditioning (SL 42)  
Hospital equipment (SL 18)  
Illumination and lighting fittings (SL 14)  
Industrial instruments, etc. (SL 17)  
Iron and steel (SL 24)  
Laboratory apparatus (SL 23)  
Leather, plastics, rubber (SL 12)  
Local authority purchasing officers' guide (SL 28)  
Machine tools (SL 20)  
Mechanical engineering (SL 6)  
Nomenclature, symbols and abbreviations (SL 29)  
Non-ferrous metals (SL 19)  
Nuclear energy (SL 36)  
Packaging and containers (SL 15)  
Paints, varnishes, paint ingredients and colours for paints (SL 9)  
Personal safety equipment (SL 30)  
Petroleum industry (SL 38)  
Printing and stationery, paper and board (SL 22)  
Road engineering (SL 32)  
Shipbuilding (SL 40)  
Textiles and clothing (SL 33)  
Welding (SL 7)

*Applications should be addressed to:*

**BRITISH STANDARDS INSTITUTION**

Sales Branch

Telephone: 01-837 8801

Newton House, 101/113 Pentonville Rd., London, N.1



## BRITISH STANDARDS INSTITUTION

The British Standards Institution was founded in 1901 and incorporated by Royal Charter in 1929.

The principal objects of the Institution as set out in the charter are to co-ordinate the efforts of producers and users for the improvement, standardization and simplification of engineering and industrial materials; to simplify production and distribution; to eliminate the waste of time and material involved in the production of an unnecessary variety of patterns and sizes of articles for one and the same purpose; to set up standards of quality and dimensions, and to promote the general adoption of British Standards.

In carrying out its work the Institution endeavours to ensure adequate representation of all viewpoints. Before embarking on any project it must be satisfied that there is a strong body of opinion in favour of proceeding and that there is a recognized need to be met.

The Institution is a non-profit-making concern. It is financed by subscriptions from members—individuals, companies, technical and trade associations, and other bodies interested in its work, by a Government grant and by the sale of its publications. Membership of the Institution confers a number of specific rights and privileges. The demands on the services of the Institution are steadily increasing and can only be met if continuing and increased support is provided by those who use British Standards.

Universal Decimal Classification 678.4.01 : 537. 226

*Printed in England by Gaylard & Son Ltd, London, S.E.14*

(300/6/70)